



This is a certificate of compliance to certify that the bearer has successfully completed the requirements of the above scheme which include the testing of products, the initial assessment, and are subject to continuing annual assessments of their compliance and testing of samples of products taken from production (as applicable to the scheme) and has been registered within the scheme for the products detailed.

Certificate of Compliance

You have been awarded:

Intertek WH US + C Mark for Category D - Door/frame Assemblies

Standards: CAN / ULC S104 (2015) (R2020), UL 10(b) (2008) (R2020), UL 10(c) (2016) Ed. 3 (R:27 May 2021), NFPA 252 (2022)

Certificate number: WH125-44848902

Organization: Saudi Maden Tech for Manufacturing
3rd Industrial city, Prince Saudi Abdullah Street
Jeddah, Makkah 22772
Kingdom of Saudi Arabia

Product: SMT - Latched Steel Door And Frame Assembly With Mineral Wool Infill - 90 Minutes - UL 10C

Spec ID: 88337

Fire Rating: 60 Min PP Category D Door/Frame Assemblies, 90 Min PP Category D

Door/Frame Assemblies, 45 Min PP Category D Door/Frame Assemblies

Listing Information: See following page(s)

Certification body: Intertek Testing Services NA, Inc.

Initial registration: December 04, 2025

Date of expiry: December 31, 2026

Issue status: 1

Authorized By: 
Jean-Philippe Kayi, Director of Certification

Intertek Testing Services NA, Inc.
545 E. Algonquin Road, Ste H., Arlington Heights, IL 60005 USA
Phone: 847-438-5667 Fax: 847-438-7320

www.intertek.com

The certificate and schedule are held in force by regular annual surveillance visits by Intertek Testing Services NA, Inc. and the holder is under strict contact Intertek to maintain its status. This certificate remains the property of Intertek Testing Services NA, Inc. and must be returned to them on demand. This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client, in accordance with the agreement. In any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorized to permit copying or distribution of this certificate and then only as he expressly. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek mark for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of ensuring appropriate usage of the Certification mark in accordance with the agreement. They are not for the purpose of production quality control and do not release the Client of their obligations in this respect.

LISTING INFORMATION

Product Covered

SMT - Latched Steel Door And Frame Assembly With Mineral Wool Infill - UL 10C

Product Description

Door frame is constructed with 1.5mm to 3.0mm thick galvanized steel sheet or cold rolled steel with 150mm to 330mm jamb depth with cement grouting.

Door leaves constructed with 1.2mm to 1.8mm thick galvanized steel sheet or cold rolled steel and infilled with mineral wool of up to 100kg/m³ density. Overall leaf thickness 45mm.

Maximum Tested Sizes:

Assembly		Rating	Size
Single leaf door assembly	Frame	1-1/2 hours (90 minute)	1319 x 2488mm (w x h)
	Leaf		1213 x 2420 x 45mm (w x h x thk.)
Double leaf door assembly	Frame	1-1/2 hours (90 minute)	2538 x 3088mm (w x h)
	Leaf (each)		1215 x 3020 x 45mm (w x h x thk.)

Vision panel size:

Maximum width (Visible)	Maximum height (Visible)	Maximum Area (Visible)
450mm	450mm	0.2025m ²

Allowances and Limitations:

1. Minimum Latch Throw - 19mm (Listed mortise lockset). Standard 3-point latching for double doors - center latching on active leaf and top/bottom latching with flush bolts on the inactive leaf.
2. Welded steel astragal is required for double leaf doors on inactive leaf.
3. Fully welded edge seams are allowed with the tested design.
4. Vision panel is allowed with 5mm thick Firelite or alternative listed ceramic glazing -Glass size: 490mm x 490mm (w x h) | Visible size: 450mm x 450mm (w x h), Vision Panel aperture is to be reinforced using a 1.5mm thick steel C-channel.
5. Listed steel louver is allowed, Maximum size – 800 x 800mm (w x h). Can be used below 1m height of the door leaf. Louver Panel aperture is to be reinforced using a 1.5mm thick steel C-Channel.
6. Welded, Split frame or knockdown frame is allowed; a 4-sided frame is also allowed.
7. Wrap around frame with a return bend is allowed
8. Single and double rebated frame construction are allowed.
9. Embedded frame is allowed such that the frame is embedded inside the floor.
10. Frame anchors: Expansion, masonry and stud anchors are allowed as per manufacturer's instructions.
11. Frames must be installed in fire rated masonry walls and filled with cement grout.
12. Category H listed seals are allowed for installation in frame kerf. Seals must be listed according to UL 10C standard for use in the steel fire doors.
13. Flush door construction is allowed.
14. Double egress doors: Not allowed

The product noted above has been evaluated according to the requirements of the UL 10C standard. Also meets the requirements of UL 10B (Negative Pressure Fire Rating) and NFPA 252 (Positive Pressure Fire Rating) & CAN / ULC S104 (2015) (R2020).

The door and frame assembly noted above is eligible to bear the "S" (for Smoke & Draft Control assemblies) if a listed "Category H - Smoke & Draft Control Gasket" has been applied to the assembly. Please refer to Category H for individual gasket manufacturer's listings.

Note - Entire Assembly (door, frame and hardware) is shipped from the manufacturing facility as a complete package.